

Addendum Number 1

September 15, 2017

**County of Monroe, Michigan  
Request for Proposals  
Youth Center Roofing Project 2017**

This addendum is issued prior to the receipt of proposals and award of contract, in order to provide changes and or clarifications in the proposal requirements issued by the County. This addendum will become part of the Request for Proposal and any contractual obligations shall be met by the respective parties to the ensuing contract.

Please amend the Request for Proposal dated September 15, 2017 by including in the RFP the following information and clarifications:

A. Page 2, Cover Letter

Change in General scope of the work for the **BASE BID** is described below:  
paragraph number 1:

1. Remove and dispose of existing asphalt shingles on the five (5) sloped roof areas. **Prepare the roof deck by installing a cover board to serve as a proper substrate. The cover board may be a ½" layer of wood fiber board, an HD ISOGard cover board or a ½" DensDeck gypsum cover board to receive the new roof membrane** removing any sharp protrusions or nails.

The RFP Due Date of Monday, October 2, 2017 at 4:00 p.m. remains unchanged.