

**County of Monroe, Michigan  
Request for Proposals  
Jail Cell Door Repair/Replacement**

This addendum is issued prior to the receipt of proposals and award of contract, in order to provide for changes and or clarifications in the proposal requirements issued by the County of Monroe, Michigan. This addendum will become part of the Request for Proposal and any contractual obligations shall be met by the respective parties to the ensuing contract.

Please amend the Request for Proposal dated March 03, 2017 by including in the RFP the following information and clarifications:

A. On pages 5 and 6, Project Description:

1. Dayroom (D), the jam width on all the doors is two (2) inches, due to the close proximity to structural supports; the electro-mechanical (Airteq 9924) locking mechanism will not work on some doors. Therefore, utilize the Airteq 9524 (Lil Ricky) in its place.
2. Dayroom (E), the jam width on all the doors is two (2) inches, due to the close proximity to structural supports; the electro-mechanical (Airteq 9924) locking mechanism will not work on some doors. Therefore, utilize the Airteq 9524 (Lil Ricky) in its place.
3. Dayroom (F), the jam width on all the doors is two (2) inches, due to the close proximity to structural supports; the electro-mechanical (Airteq 9924) locking mechanism will not work on some doors. Therefore, utilize the Airteq 9524 (Lil Ricky) in its place.
4. Dayroom (G), eliminate the request for three (3) new keys. The reason being the locks are not being changed.

B. On page 6, Electrical:

1. If you chose, you may include an electrical alternate bid for the project. The current low voltage 24DC power supply is located in the door position switch located on the door header surface. The scope of the work is to include conduit and wire from the door position switch to the new locking mechanism on all the doors in dayrooms D, E, and F.

C. Proposal due date remains unchanged: **Friday, April 24, 2015 at 4:00 P.M.**

If you have any questions as to the intent of the above changes and clarifications to the Request for Proposal, please do not hesitate to contact the undersigned using the contact information in the RFP.

Sincerely,



Michael G. Bosanac  
Administrator/Chief Financial Officer