

MONROE COUNRY ANIMAL CONTROL VENTILATION PROJECT

This addendum is issued prior to the receipt of proposals and award of contract, in order to provide for changes and or clarifications in the proposal requirements issued by the County of Monroe, Michigan. This addendum will become part of the Request for Proposal and any contractual obligations shall be met by the respective parties to the ensuing contract.

Please amend the Request for Proposal dated April 29, 2019 by including in the RFP the following information and clarifications:

Specifications/Drawings:

SECTION 23 0700-HVAC INSULATION

B. Ductwork:

Externally insulate all supply air ductwork on roof with 6 pound density, 2 inches thick, minimum R-6 insulation value, rigid fiberglass insulation, maximum thermal conductivity (k) at 75 Degrees Fahrenheit mean temperature, 0.23 BTU/HR square foot F°/inch with foil face vapor seal finish. Insulation shall be Owens-Corning 506-FRK. Cover with a weather tight insulation.

Ductwork internal to building does not require insulation.

Drawings:

Drawings M-1 (drawings not reissued at this time)

1. Route 1 ¼ inch gas from existing 3 inch 2-psi gas piping on roof. Provide regulator at unit. Confirm gas pressure before sizing regulator.

Cover Page and Page 5 of Cover Letter:

Proposal due date is changed to: Tuesday, May 28, 2019 at 4:00 P.M.

The final date for submitting a proposal for the project is Tuesday, May 28, 2019 at 4:00 p.m. Eastern Standard Time.

If you have any questions as to the intent of the above changes and clarifications to the Request for Proposal, please do not hesitate to contact the undersigned using the contact information in the RFP.

Sincerely,
Troy Goodnough
Major of Jail Operations